

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:43 pm

PWS ID: UTAH23003 **Name:** STANSBURY PARK IMPROVEMENT DISTRICT
Legal Contact: STANSBURY PARK IMPR DISTR **Rating:** Approved
BRETT PALMER **Rating Date:** 09/13/1979
Address: #10 PLAZA **Activity Status:** Active
STANSBURY PARK, UT 84074
Phone Number: 435-882-7922
City Served (Area):
County: TOOELE COUNTY
System Type: Community **Last Inv Update:** 05/28/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 12/31/2010 **Total Dsgn Cap:**
Population: 8,400 **Surveyor:** KATE JOHNSON **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	PALMER, BRETT		435-882-7922	435-882-4340	spid@trilobyte.net

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	1,887
Commercial	Metered	0	97
			1,984 Total Svc Connections

Storage

Total Storage: 3,100,000 GAL **Number of Units:** 2 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	# 1 WATER TANK	Ground	1,500,000 GAL	Concrete	4496	A	NO
ST002	#2 WATER TANK	Ground	1,600,000 GAL	Concrete	4496	A	NO

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL #1 (EAST)	Active	WL	16	2500 GPM	3,000 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	WELL #2 (WEST)	Active	WL	16	2450 GPM	2,900 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS003	CLEGG WELL	Active	WL	12	1000 GPM	800 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS004	DISTRICT WELL #4	P	WL				Yes	GW	Permanent		

*Reports measured flow for wells, approved design capacity for all other sources.